



**STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT**



1 of 2

Facility Information Section

Satisfactory

Permit Number: 49-60-00782
 Type: Public Pool > 25000 Gallons
 Owner: Anthem Park Community Development District
 Person In Charge: Messenger, Kristin Phone: (407) 396-7666
 Pool Operator: unknown, Alex - Tidy Pools Phone: 407-844-1182
 Name of Facility: Anthem Park Community Park Swimming Pool
 Address: 2090 Continental Street
 City, Zip: Saint Cloud 34769

Inspection Results Information Section

Purpose: Routine	Begin Time: 10:05 AM	Correct By: Next Inspection
Inspection Date: 6/18/2015	End Time: 10:37 AM	Re-Inspection Date: None

Additional Information Section

VOLUME	126000
POOL LOAD	139
FLOW RATE	698
FILTER TYPE	DEV
22. Free Chlorine	3.8
23. pH	7.4
24. Chlor. Stabilizer	40
33. Flowmeter	660
34. Thermometer	85

Items marked below are not in compliance the requirements of Chapters 64E-9 of the Florida Administrative Code and must be corrected. Continued operation of this facility without making these corrections is a violation of Chapter 64E-9 of the Florida Administrative Code and Chapters 386 and 514, Florida Statutes. Violations must be corrected as indicated in the Results section above or an administrative fine or other legal action will be initiated.

Violation Markings Section

<ul style="list-style-type: none"> Pool Area 1. Appearance/Algae Control 2. Deck/Walkways 3. Tile/Pool Finish 4. Depth Markers 5. Handrail/Ladder 6. Step Markings 7. Main Drain Grate 8. Gutter Grates/Skimmer 9. Lighting 10. No Dive Markings 11. Diving Board 12. Pool Cover 13. Pool Side Shower Pool Safety 14. Life Hook w/Pole 15. Life Ring w/Rope 16. Safety Line/2 Marking 	<ul style="list-style-type: none"> 17. Rules Posted 18. Certification Sanitary Facilities 19. Supplies 20. Clean Water Quality 21. Approved Test Kit 22. Free Chlor./Bromine 23. pH 24. Chlor. Stabilizer 25. Spa Requirements Equipment Room 26. Wading Pool: Quick Dump 27. Water Level/Control 28. Disinfection Feeder 29. pH Feeder 30. Chem. Container Label 31. Filter Pump 	<ul style="list-style-type: none"> 32. Vacuum Cleaner 33. Flowmeter 34. Thermometer 35. Pressure/Vacuum Gauge 36. Equip. Room 37. Cross Connection 38. Gas Chlor. Equip. 39. Waste Water Disposal 40. D.E. Separator 41. Other Equipment 42. Equipment Change 43. Approved Chemicals 44. Maintenance Log 45. Inspection Posted 46. Electrical Equip. 47. Fences 48. Other 49. Other
---	---	---

NOTE: It is unlawful to modify a public pool or its equipment without prior approval from the local building department and submitting an application to DOH.

Inspector Signature:

Client Signature:



STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC POOL AND BATHING PLACE
INSPECTION REPORT



2 of 2

General Comments Section

No General Comments Available

Violations Comments Section

35. Pressure/Vacuum Gauge

Vacuum gauge reads zero.

Pressure/Vacuum Gauges. 64E-9.007(5)(b). All vacuum filter systems shall have a vacuum gauge before the pump. All pressure filter systems shall have a pressure gauge mounted before and after the filter.

Inspection Conducted By: Jamie Couitt (51960)

Phone: (407) 742-8606 ex.

Received By: Signed

Date: 6/18/2015

Inspector Signature:

A handwritten signature in black ink, appearing to be "J. Couitt".

Client Signature:

A handwritten signature in black ink, appearing to be "Email".